

Name: Nassau UPS**Intended use of the product**

Electrical battery power supply equipment, intended to be used in smoke and heat control systems, only in combination with a Nassau electrical door operator.

Manufacturer

NASSAU DOOR A/S

Krogagervej 2

DK-5750 Ringe

Denmark

Tel. +45 62 62 23 46

System of assessment and verification of constancy of performance of the product (AVCP): System 1**Harmonised standard:** EN 12101-10: 2005**Notified body:** ift Rosenheim GmbH 0757**Declaration of performance cf. harmonised technical specification EN 12101-10**

Essentials characteristic	Niveau/class	Harmonised technical specification
Operational reliability	B	Chapter 6, EN 12101-10:2005
Environmental class:	Class 1	Chapter 7, EN 12101-10:2005
Performance parameters under fire conditions:	Class B	Chapter 4.1, EN 12101-10:2005
Response time	Class A	Chapter 4.1, EN 12101-10:2005
Function	Fulfilled	Chapter 6.2.2, EN 12101-10:2005

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above. Signed for and on behalf of the manufacturer by

15/05/2018



CEO Jens Flesner

Conditions for use:

Nassau Door A/S refers to the accompanying door manual before use. Modifications or changes made to the product which are not authorised by the manufacturer will invalidate this document.